

Chapter 17.40

MECHANICAL CODE

(1408-5/68, 1628-2/71, 1938-10/74, 2172-3/77, 2235-12/77, 2282-5/78, 2337-1/79, 2431-7/80, 2747-2/85, 2976-12/88, 3022-12/89, 3147-7/92, 3312-2/96, 3425-7/99, 3574-10/02, 3790-1/08, 3895-12/10)

Sections:

- 17.40.010 Adoption
- 17.40.020 Title
- 17.40.025 Administration
- 17.40.030 (Repealed – Ordinance No. 3425 - 7/99)
- 17.40.040 Commercial Kitchen Hoods
- 17.40.045 (Repealed – Ordinance No. 3790 – 1/08)
- 17.40.050 (Repealed – Ordinance No. 3790 – 1/08)
- 17.40.060 (Repealed – Ordinance No. 3790 – 1/08)

17.40.010 Adoption. There is hereby adopted by the City Council by reference that certain code known as the 2010 California Mechanical Code, and the whole thereof, including appendices A, B, and C, except as hereinafter provided but excluding chapters 1 and 14 thereof. Such code, and amendments thereto, is hereby adopted and incorporated, pursuant to California Government Code §50022.2 et seq., and Health and Safety Code §18941.5, as fully as though set forth at length herein, for the purpose of protecting public health and safety by prescribing by minimum standards for the use, design and installation of heating, ventilating, comfort-cooling equipment and refrigeration systems; by requiring a permit and inspection for the installation, alteration and replacement of said equipment. From the date on which this chapter takes effect, the provisions thereof shall be controlling within the corporate limits of the City of Huntington Beach.

(1938-10/74, 2172-3/77, 2431-7/80, 2747-6/85, 2976-12/88, 3022-12/89, 3147-7/92, 3312-2/96, 3425-7/99, 3574-10/02, 3790-1/08, 3895-12/10)

17.40.020 Title. This chapter shall be known as the "Huntington Beach Mechanical Code," may be cited as such, and will be referred to herein as "this code." (1408-5/68, 1628-2/71, 1938-10/74, 2431-7/80, 2747-6/85)

17.40.025 Administration. For administrative provisions of the code see Chapter 1 of the Huntington Beach Building Code. (3892-12/10)

17.40.040 Commercial Kitchen Hoods. §508.1 is hereby amended by adding the following exception: (3574-10/02, 3790-1/08)

§508.1 Exceptions.

- (1) A hood will not be required where the only warming appliance in the establishment consists of an enclosed electric convection oven having a capability of reaching a maximum temperature of 350° F. The oven must be listed by an approved testing agency and approved by the Orange County Health Department.
(3147-7/92, 3312-2/96, 3425-7/99, 3574-10/02, 3790-1/08)
- (2) A hood is not required over low temperature sanitizing type dishwashers with wash and rinse water temperatures that do not exceed 140 degrees Fahrenheit. (3892-12/10)